

Energy meter's technical data

Active Energy Accuracy	According to IEC 62053-21	class 1
Reactive Energy Accuracy	According to IEC 62053-23	Class 2
Nominal Voltage		230V
Nominal Frequency	---	50Hz
Nominal (Maximum) Current	Continuous current	5(100)A
	Short duration	3000A for 0.5 cycle